

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1327

Dated: 03/02/2024

It is certified that an inspection team headed by Prashant Kumar
 (Name of Officers with designation) from Juniar Engineer Jal Sanathan
 (Name of Department/ Office) inspected the Vivekananda The Global School
 (Name & Address of the school) on 03/02/2024 (date of inspection) and found that the
Vivekananda The Global School (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of Three years

Signature with Seal

03/02/24 अवर अभियन्ता
 बाँसी डिवीजनल जल संस्थान
 कोच (उरई)

Name

: Prashant Kumar

Designation

: J. E. Jal Sanathan

Name & Address of the Office/Department:.....

Public Health Engineer Korch (Ura)

To

Vivekananda The Global SchoolChamaraseng Nahar Mang Korch (Jalun)

(Name & Address of the Institution)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.



WATER TESTING LABORATORY

Orai Khand U.P. Jal Nigam Orai (Jalaun)

Chemical analysis of Water

MR No - 54961

Report No. - 1327

Date: 02/02/2023

Village/Town - Koneh Code No. Block - Koneh Distt. - Jalaun

Water Source - Tube well Location - Vivekananda The Global School campus

Name & Designation Of Sample Collector - Prashant Kumar, Junior Engineer

Date of Analysis -

S.No.	Physical Examination	Unit	Test Result	Indian Standard	
				Desirable limit	Permissible
A					
1-	Turbidity NTU	NTU	1.1	1	5
2-	Colour	"	Less	5	25
3-	Odour	"	Less	-	-
4-	PH Value	"	7.47	7.0 to 8.5	<6.5 to >9.2
5-	Total dissolved solids	ppm	77	500	2000
B	Chemical Analysis in	ppm			
6-	Total Hardness as (CaCO ₃)	"	100	200	600
a-	Calcium as (Ca)	"	20	75	200
b-	Magnesium as (mg)	"	10	30	100
7-	Chlorides as (Cl)	"	15	200	1000
8-	Sulphates as So ₄	"	0	200	400
9-	Fluorides as (F)	"	0.6	1.0	1.5
10-	Nitrates (NO ₃)	"	0.221	45	<45
11-	Nitrite (NO ₂)	"	0.023	0.1	1.0
12-	Iron as (Fe)	"	0.01	0.1	0.3
13-	Residual Chlorine	"	-	0.2	1.0
14-	Alkalinity as (CaCO ₃)	"			
a-	Phenolphthalein	"			
b-	Methyl Orange	"	110	200	600
15-	Arsenic as (As)	"	0.0	0.01	0.05
16-	Conductivity	Micro mho	-		
17-	Presence (By H ₂ S Strip)	"	-	0	0
18-	E-Coli (MPN) 100ml	"		0	0
19-					
20-					
21-					
22-					

Test Result - Satisfactory

Remarks

J.E.
अवर अभियन्ता
झाँसी डिवीजनल जल संस्थान
कोच (उरई)

A.E.
सहायक अभियन्ता
झाँसी डिवीजनल जल संस्थान
कोच (उरई)

Chemist

